



Tedlar® Wallcoverings only by DuPont “Style that Endures”

The products that we use to build and furnish our indoor environments can have a significant impact on indoor air pollution levels. Products that have achieved Greenguard Certification are scientifically proven to meet some of the world’s most rigorous, third-party chemical emissions standards – helping reduce indoor air pollution and the risk of chemical exposure while aiding in the creation of healthier indoor environments.

Greenguard Certified and Greenguard Gold:



Released by UL Environment
 Date Issued: October 17, 2018
 Product ID#: 1000532050-1813408
 Test Report #: 1000532050-1813408
 ©2018 UL LLC
 BCME



GREENGUARD CERTIFICATION TEST REPORT

Test Group	Wallcovering - 01				
Category	Building Products				
Test Type	Initial				
Test Method	UL 2821 "GREENGUARD Certification Program Method for Measuring and Evaluating Chemical Emissions From Building Materials, Finishes and Furnishings Using Dynamic Environmental Chambers"				
	Environment	TVOC	Formaldehyde	Total Aldehydes	CREL/TLV
GREENGUARD	Office	✓	✓	✓	✓

GREENGUARD Acceptable IAQ Criteria	168 Hour Product Measurement	Product Compliance for IAQ
TVOC ^a	≤ 0.5 mg/m ³	0.37 mg/m ³ Yes
Formaldehyde	≤ 0.05 ppm	< 0.003 ppm Yes
Total Aldehydes ^b	≤ 0.10 ppm	< 0.003 ppm Yes
4-Phenylcyclohexene	≤ 0.0065 mg/m ³	< 0.003 mg/m ³ Yes
Individual VOCs	all ≤ 1/10 TLV	----- ^c Yes

^a "TVOC" is the sum of all VOCs measured via TD/GC/MS which elute between n-hexane (C₆) and n-hexadecane (C₁₆) quantified using calibration to a toluene surrogate.
^b "Total Aldehydes" is the sum of all measured normal aldehydes from formaldehyde to nonanal, plus benzaldehyde. Heptanal through nonanal are analyzed using TD/GC/MS. The remaining aldehydes are analyzed using HPL/UV methodology. All aldehydes are quantified to authentic standards.
^c All individual VOCs detected met the criteria of less than 1/10 the ACGIH established threshold limit values (TLVs).

GREENGUARD Gold	Classroom	✓	✓	✓	✓
✓ - meets criteria; X - over criteria					
Laboratory Approval	 Allyson M. McFry Chemistry Laboratory Director				

